

Annual Drinking Water Quality Report

CANYON PARK WSC

Public Water System ID: TX1870034

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year, for the period of January 1 to December 31, 2025. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. (Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (936) 646-3529).

For more information regarding this report, contact:

Name: Jim Marxen

Phone: 936-646-3529 – Water Office phone

Canyon Park WSC holds a monthly board of director’s meeting the third Thursday of each month at 6:00pm in the Canyon Park Clubhouse. The public is welcome to attend.

Sources of Drinking Water

CANYON PARK WSC is Ground water (2 wells – Gulf Coast aquifer).

Our water source(s) and source water assessment information are listed below:

Source Name		Type of Water	Report Status	Location
1 - LONE OAK / PLANT	1 - 103 E LONE OAK DR	Ground water	Active	Gulf Coast Aquifer
5 - 103 E LONE OAK DR	5 - 103 E LONE OAK DR	Ground water	Active	Gulf Coast Aquifer

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants – including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants – which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. CANYON PARK WSC is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact CANYON PARK WSC at 936-239-6010. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

A service line inventory has been prepared and can be accessed at CanyonParkWaterSupply.com.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Avg: Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.

RAA: Running Annual Average.

LRAA: Locational Running Annual Average.

mrem: millirems per year (a measure of radiation absorbed by the body).

ppb: micrograms per liter (ug/L) or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water.

picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

na: not applicable.

Disinfectant Residual

All public water systems in Texas are required to disinfect drinking water to ensure control of microbial contaminants. Disinfectants are water additives used to control microbes.

Disinfectant	Year	Average Level	Unit	Range	MRDL/MRDLG Goal
Free Chlorine	2025	1.6	Mg/L	0.5 – 2.85	4/4

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Lead and Copper	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low - high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2021 - 2023	0	0	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2021 - 2023	0	0	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	273 CANYON PARK LN, ONALASKA	2025	1	1	ppb	60	0	By-product of drinking water disinfection
TTHM	273 CANYON PARK LN, ONALASKA	2025	10	9.6	ppb	80	0	By-product of drinking water chlorination

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
BARIUM	8/20/2024	0.181	0.181	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
DIBROMOCHLOROMETHANE	9/23/2025	3.8	2.7 - 3.8	UG/L	0	0.06	
FLUORIDE	8/20/2024	0.53	0.53	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	2/22/2022	3.71	2.65 - 3.71	pCi/L	5	0	Erosion of natural deposits

GROSS ALPHA, EXCL. RADON & U	2/22/2022	9	6.5 - 9	pCi/L	15	0	Erosion of natural deposits
GROSS ALPHA, INCL. RADON & U	2/22/2022	9	6.5 - 9	pCi/L	0	0	Erosion of natural deposits
GROSS BETA PARTICLE ACTIVITY	5/18/2022	10.2	9.1 - 10.2	pCi/L	50	0	Decay of natural and man-made deposits.
RADIUM-226	2/22/2022	3.71	2.65 - 3.71	PCI/L	5	0	Erosion of natural deposits

Violations

During the period covered by this report we had the below noted violations.

Violation Period	Analyte	Violation Type	Violation Explanation
10/17/2024 - 1/10/2025	LEAD AND COPPER RULE REVISIONS	LSL INVENTORY-INITIAL	Initial inventory was submitted but had been rejected without us knowing. Resubmitted.
10/17/2024 - 1/10/2025	LEAD AND COPPER RULE REVISIONS	LSL REPORTING-INITIAL	Initial inventory was submitted but had been rejected without us knowing. Resubmitted.
7/1/2025 - 6/20/2025	CONSUMER CONFIDENCE RULE	CCR ADEQUACY/AVAILABILITY/CONTENT	Inadequate Consumer Confidence Report (CCR) or failure to deliver a CCR Certification form to the state on time.
12/1/2025 - 12/31/2025	REVISED TOTAL COLIFORM RULE (RTCR)	MONITORING, ROUTINE, MAJOR (RTCR)	Failed to collect routine or replacement coliform samples. This happened when we transitioned to a new water operations firm.

Additional Required Health Effects Language:

Lithium (83.5 ug/L) - Lithium is a naturally occurring metal, has numerous commercial uses including as a main component of batteries, and is likely found in a variety of foods. Lithium is also used as a pharmaceutical to treat certain medical conditions.

Lithium is on the EPA's Fifth Contaminant Candidate List (CCL 5), a priority list of drinking water contaminants that may require future regulation under the Safe Drinking Water Act. Lithium was selected for the Fifth Unregulated Contaminant Monitoring Rule (UCMR 5) to better inform research and determine whether lithium poses health risks to people through drinking water from PWSs

The EPA does not currently have an EPA Health Advisory for lithium in drinking water. The screening Health Reference Level (HRL) of 10 µg/L from CCL 5 is based on adverse effects observed in patients administered lithium therapeutically, not at levels expected to be found in drinking water.

Lithium cannot be removed by heating, boiling, or disinfecting water. Certain drinking water treatment approaches can reduce exposure. The U.S. Food and Drug Administration (FDA) has not established a standard for lithium in bottled water.

Bromodichloromethane (1.8 ug/L) - is a colorless, nonflammable liquid that dissolves in water but can also evaporate into air. It is primarily formed when chlorine or chlorine-containing chemicals react with naturally occurring organic matter in water, such as plant material or algae, during water treatment.

Review Data | SDWARS

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	200.7	lithium	83.5	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	11CI-PF3OUdS	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	4:2 FTS	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	6:2 FTS	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	8:2 FTS	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	9CI-PF3ONS	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	ADONA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	HFPO-DA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	NFDHA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFBA	< MRL	PWS/EPA Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure $\mu\text{g/L}$	Status
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFBS	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFDA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFDoA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFEESA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFHpA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFHpS	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFHxA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFHxS	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFMBA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFMPA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFNA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFOA	< MRL	PWS/EPA Approved

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFOS	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFPeA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFPeS	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	533	PFUnA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	537.1	NEtFOSAA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	537.1	NMeFOSAA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	537.1	PFTA	< MRL	PWS/EPA Approved
TX1870034	10001	EP001	SE1	Eastex Environmental Laboratory, Inc.	117980P	6/19/24	537.1	PFTTrDA	< MRL	PWS/EPA Approved



**Texas Department of State
Health Services**

***NITRATE
Analysis Report**



Submitter ID # (PWS ID #): 1870034

CANYON PARK WSC
SIMARD, ROBERT
PO BOX 1928
ONALASKA, TX 77360-1928

Date Reported : 09/16/2025
Report ID# : 20250916082938AH39041

Lab Sample ID# : AH39041
Sample Priority : NORMAL
TCEQ Sample ID: 2535479

Water Source :
Entry Point(s) : EP001

Date Collected : 09/02/2025 10:02
Date Received : 09/03/2025

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Nitrate as N ¹	< 0.25	mg/L	EPA 353.2	09/03/2025 14:23	MB

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted('1') meet all TNI (2016 Standard) requirements.

Authorized by Team Lead NPATEL on 09/12/2025

**Pesticides by Method 508.1
Analysis Report**

Address: 1100 W 49th St
Austin, TX 78756
Mail: PO Box 149347, MC-1947
Austin, TX 78714-9347
envsciadmin@dshs.texas.gov
www.dshs.state.tx.us
512-776-7587

**Texas Department of State
Health Services**

Submitter ID # (PWS ID #): 1870034

CANYON PARK WSC
SIMARD, ROBERT
PO BOX 1928
ONALASKA, TX 77360-1928





Date Reported : 10/30/2025
Report ID# : 20251030082210AH39260

Lab Sample ID# : AH39260
Sample Priority : NORMAL
TCEQ Sample ID: 2508275

Water Source :
Entry Point(s) : EP001

Date Collected : 09/02/2025 10:02
Date Received : 09/03/2025
Date Analyzed : 09/16/2025

Conc. Units : ug/L
Method : 508.1 Rev. 2.0
Analyst : TS
Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier
Chlordane ¹	<0.2	
Endrin ¹	<0.01	
Heptachlor epoxide ¹	<0.02	
Toxaphene ¹	<1.	
Screened Compounds	Result	Qualifier
Aroclor 1016 ²	<0.08	
Aroclor 1221 ²	<20.	
Aroclor 1232 ²	<0.5	
Aroclor 1242 ²	<0.3	
Aroclor 1248 ²	<0.1	
Aroclor 1254 ²	<0.1	
Aroclor 1260 ²	<0.2	

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(¹) meet all TNI (2016 Standard) requirements. The test results for analytes noted(²) meet all TNI (2016 Standard) requirements for Aroclor Identification. Aroclor quantitation is not accredited.

Authorized by Team Lead JHE on 10/29/2025



**Texas Department of State
Health Services**

**Semivolatiles Organic
Analysis Report**

Submitter ID # (PWS ID #): 1870034

CANYON PARK WSC
SIMARD, ROBERT
PO BOX 1928
ONALASKA, TX 77360-1928

Date Reported : 10/30/2025
Report ID# : 20251030082210AH39260

Lab Sample ID# : AH39260
Sample Priority : NORMAL
TCEQ Sample ID : 2508275

Water Source :
Entry Point(s) : EP001

Date Collected : 09/02/2025 10:02
Date Received : 09/03/2025
Date Analyzed : 09/18/2025
Extraction Date : 09/05/2025

Conc. Units : µg/L
Method : EPA 525.2
Analyst : RR
Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier	Monitored Compounds continued	Result	Qualifier
Alachlor ¹	<0.2		Dimethylphthalate	<2.1	
Atrazine ¹	<0.1		Fluorene	<0.21	
Benzo[a]pyrene ¹	<0.02		2,2',3,3',4,4',6-Heptachlorobiphenyl	<0.51	
alpha-Chlordane	<0.2		2,2',4,4',5,6'-Hexachlorobiphenyl	<0.21	
gamma-Chlordane	<0.2		Indeno[1,2,3-cd]pyrene	<0.21	
trans-Nonachlor	<0.2		Metolachlor	<0.21	
Di(2-ethylhexyl) adipate ¹	<0.6		Metribuzin	<0.21	
Di(2-ethylhexyl) phthalate ¹	<0.6		Naphthalene	<0.21	
Heptachlor ¹	<0.04		2,2',3,3',4,5',6,6'-Octachlorobiphenyl	<0.51	
Hexachlorobenzene ¹	<0.1		2,2',3',4,6-Pentachlorobiphenyl	<0.21	
Hexachlorocyclopentadiene ¹	<0.1	*	Phenanthrene	<0.21	
Lindane ¹	<0.02		Propachlor	<0.21	
Methoxychlor ¹	<0.1		Pyrene	<0.21	
Simazine ¹	<0.07		2,2',4,4'-Tetrachlorobiphenyl	<0.21	
Monitored Compounds	Result	Qualifier	2,4,5-Trichlorobiphenyl	<0.21	
Acenaphthene	<0.21		Trifluralin	<0.21	
Acenaphthylene	<0.21		Comments:		
Aldrin	<0.21	*	* - This analyte has known instability and/or method performance issues and quantitation should be considered approximate.		
Anthracene	<0.21		The test results on this report relate only to the sample identified on this report. The test results for analytes noted(¹) meet all TNI (2016 Standard) requirements.		
Benzo(a)anthracene	<0.21		Authorized by Team Lead JHE on 10/29/2025		
Benzo[b]fluoranthene	<0.21				
Benzo[g,h,i]perylene	<0.21				
Benzo[k]fluoranthene	<0.21				
Bromacil	<0.21				
Butachlor	<0.21				
Butylbenzylphthalate	<2.1				
2-Chlorobiphenyl	<0.21				
Chrysene	<0.21				
Dibenz[a,h]anthracene	<0.21				
Di-n-butylphthalate	<2.1				
2,3-Dichlorobiphenyl	<0.21				
Dieldrin	<0.21				
Diethylphthalate	<2.1				

**Texas Department of State
Health Services**

**Volatile Organic Compounds by GC/MS
Analysis Report**



Submitter ID # (PWS ID #): 1870034

CANYON PARK WSC
SIMARD, ROBERT
PO BOX 1928
ONALASKA, TX 77360-1928

Date Reported : 09/18/2025
Report ID# : 20250918082745AH39184

Lab Sample ID# : AH39184
Sample Priority : NORMAL
TCEQ Sample ID: 2503401

Water Source :
Entry Point(s) : EP001

Date Collected : 09/02/2025 10:02
Date Received : 09/03/2025
Date Analyzed : 09/04/2025
Conc. Units : µg/L
Method : EPA 524.2
Analyst : JL
Sample Cond. : Acceptable

Regulated Cmpds.	Result	Qualifier	Monitored Cmpds	Result	Qualifier
Benzene ¹	<0.5		1,2,4-Trimethylbenzene	<1.0	
Carbon tetrachloride ¹	<0.5		1,2,3-Trichlorobenzene	<1.0	
Monochlorobenzene ¹	<0.5		n-Propylbenzene	<1.0	
o-Dichlorobenzene ¹	<0.5		n-Butylbenzene	<1.0	
para-Dichlorobenzene ¹	<0.5		Naphthalene	<1.0	
1,2-Dichloroethane ¹	<0.5		Hexachlorobutadiene	<1.0	
1,1-Dichloroethylene ¹	<0.5		1,3,5-Trimethylbenzene	<1.0	
cis-1,2-Dichloroethylene ¹	<0.5		4-Isopropyltoluene	<1.0	
trans-1,2-Dichloroethylene ¹	<0.5		Isopropylbenzene	<1.0	
1,2-Dichloropropane ¹	<0.5		t-Butylbenzene	<1.0	
Dichloromethane ¹	<0.5		s-Butylbenzene	<1.0	
Ethylbenzene ¹	<0.5		Trichlorofluoromethane	<2.0	
Styrene ¹	<0.5		Dichlorodifluoromethane	<2.0	
Tetrachloroethylene ¹	<0.5		Bromochloromethane	<1.0	
Toluene ¹	<0.5		Other Compounds		
1,2,4-Trichlorobenzene ¹	<0.5			Result	Qualifier
1,1,1-Trichloroethane ¹	<0.5		Acetone	<10	
1,1,2-Trichloroethane ¹	<0.5		Acrylonitrile	<10	
Trichloroethylene ¹	<0.5		2-Butanone (MEK)	<10	
Vinyl chloride ¹	<0.5		Carbon disulfide	<1.0	
Xylenes (total) ¹	<0.5		Ethyl methacrylate	<1.0	
Monitored Cmpds.			2-Hexanone	<1.0	
	Result	Qualifier	Iodomethane	<5.0	
Chloroform	<1.0		Methyl methacrylate	<1.0	
Bromodichloromethane	1.8		4-Methyl-2-pentanone (MIBK)	<2.0	
Dibromochloromethane	2.7		Methyl-t-butyl ether (MTBE)	<0.5	
Bromoform	2.3		Tetrahydrofuran	<5.0	
Dibromomethane	<1.0		Comments:		
1,3-Dichlorobenzene	<1.0		The test results on this report relate only to the sample identified on this report. The test results for analytes noted(') meet all TNI (2016 Standard) requirements. Authorized by Team Lead CJONES on 09/17/2025		
1,1-Dichloropropene	<1.0				
1,1-Dichloroethane	<1.0				
1,1,2,2-Tetrachloroethane	<1.0				
1,3-Dichloropropane	<1.0				
Chloromethane	<2.0				
Bromomethane	<2.0				
1,2,3-Trichloropropane	<1.0				
1,1,1,2-Tetrachloroethane	<1.0				
Chloroethane	<2.0				
2,2-Dichloropropane	<1.0				
2-Chlorotoluene	<1.0				
4-Chlorotoluene	<1.0				
Bromobenzene	<1.0				
cis-1,3-Dichloropropene	<1.0				
trans-1,3-Dichloropropene	<1.0				



**Trihalomethanes by GC/MS
Analysis Report**

Address: 1100 W 49th St
Austin, TX 78756
Mail: PO Box 149347, MC-1947
Austin, TX 78714-9347
envsciadmin@dshs.texas.gov
www.dshs.state.tx.us
512-776-7587

**Texas Department of State
Health Services**

Submitter ID # (PWS ID #): 1870034

CANYON PARK WSC
SIMARD, ROBERT
PO BOX 1928
ONALASKA, TX 77360-1928



Date Reported : 10/16/2025
Report ID# : 20251016082725AH42254

Lab Sample ID# : AH42254 Water Source :
Sample Priority : NORMAL Entry Point(s) : DBP2-01
TCEQ Sample ID: 2597047

Date Collected : 09/23/2025 12:58 Conc. Units : µg/L
Date Received : 09/24/2025 Method : EPA 524.2
Date Analyzed : 10/02/2025 Analyst : JL
Sample Cond. : Acceptable

Trihalomethanes	Result	Qualifier
Chloroform	<1.0	
Bromodichloromethane	1.8	
Dibromochloromethane	3.8	
Bromoform	4.0	
Total Trihalomethanes ¹	9.6	

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted⁽¹⁾ meet all TNI (2016 Standard) requirements.

Authorized by Team Lead CJONES on 10/15/2025



**EPA 552.2 Haloacetic Acids
Analysis Report**

Address: 1100 W 49th St
Austin, TX 78756
Mail: PO Box 149347, MC-1947
Austin, TX 78714-9347
envsciadmin@dshs.texas.gov
www.dshs.state.tx.us
512-776-7587

Submitter ID # (PWS ID #): 1870034

CANYON PARK WSC
SIMARD, ROBERT
PO BOX 1928
ONALASKA, TX 77360-1928

Date Reported : 10/16/2025
Report ID# : 20251016082725AH42254

Lab Sample ID# : AH42254 Water Source :
Sample Priority : NORMAL Entry Point(s) : DBP2-01
TCEQ Sample ID: 2597047

Date Collected : 09/23/2025 12:58 Conc. Units : µg/L
Date Received : 09/24/2025 Method : 552.2 Rev 1.0
Date Analyzed : 10/03/2025 Analyst : TS
Extraction Date : 10/01/2025 Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier
Monochloroacetic acid	<2.0	
Dichloroacetic acid	<1.0	
Trichloroacetic acid	<1.0	
Monobromoacetic acid	<1.0	
Dibromoacetic acid	1.0	
Total HAA5 ¹	1.0	

Monitored Compounds	Result	Qualifier
Bromochloroacetic acid	<1.0	
Dalapon	<1.0	

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2016 Standard) requirements.

Authorized by Team Lead CJONES on 10/15/2025

